

Clark, Donella

EXHIBIT 31

DATE 2/3/2022

From: Bailey, George  
Sent: Tuesday, November 16, 2021 2:54 PM  
To: Clark, Donella  
Subject: RE: comment CUP2021-00005, Business Park Loop, Transfer Station/Recycling

Hi Donella,

Unfortunately they used Appendix B out of the IFC for the fire flow requirement and came out at 1500 gpm for 2 hours when it is regulated by our Fire Protection Ordinance requires 2500 gpm for 1 hr.

Regards,

George Bailey  
Clallam County Fire Marshal  
Plans Examiner  
Code Compliance Officer III  
360-417-2308

From: Clark, Donella  
Sent: Tuesday, November 16, 2021 12:36 PM  
To: Smith, Julie; Garcelon, Jennifer; Owens, Eli; Warren, Annette; Bailey, George; 'Fire District 3 ([bandrews@clallamfire3.org](mailto:bandrews@clallamfire3.org))'  
Cc: Goodman, Jesse; Winborn, Mary Ellen  
Subject: comment CUP2021-00005, Business Park Loop, Transfer Station/Recycling

REQUEST FOR COMMENT

Please review the [application and site plan](#) and provide comments as appropriate. Please provide comments by: **December 1, 2021**

Return comments to: Donella Clark, Principal Planner

Address: 223 E. Fourth St., Suite 5, Port Angeles, WA 98362 Phone: (360)417-2594

Fax: (360) 417-2443 E-mail: [dclark@co.clallam.wa.us](mailto:dclark@co.clallam.wa.us)

PERMIT #: CUP2021-00005 PARCEL 043015-409010

APPLICANT: Olympic Systems Properties

PROPOSAL: Transfer Station and Recycling Center

LOCATION/ACCESS: Business Park Loop, near Carlsborg Road

CRITICAL AREAS: CARA

SEPA: [ECL2021-00019](#)